



Certificate of Compliance

This certificate is issued for the following:

Polyethylene (PE) Pipe for Underground Fire Protection Service

Product Designation	O.D. Pipe Size, mm.	Pressure Rating psi (bar)	Remarks
SDR9 Pipe	110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630	200 (13.8)	-
SDR11 Pipe	110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630	150 (10.3)	-

Prepared for:

Nan Ya Plastics Corp
201 Tung Hwa N Rd.
Taipei
Taiwan

Manufactured by:

Nan Ya Plastics Corp
No. 201 Sec 2, Pei Kang Rd
Tai Bao City, Chia Yi
Taiwan

FM Approvals Class: 1613 (February 2017)

Approval Identification: PR450841

Approval Granted: April 3, 2019

To verify the product continues to be Approved please refer to www.approvalguide.com.

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA

April 11, 2019